



OFFICE OF PROCUREMENT SERVICES
315 WEST MAIN STREET, SUITE 441
PO BOX 7800
TAVARES FL 32778-7800

PHONE: (352) 343-9839
FAX: 352) 343-9473

ADDENDUM NO. 1

Date: June 17, 2015

ITB No. 15-0442

ITB Title: Fencing at South Lake Regional Park

It is the vendor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial bid or proposal response. Acknowledgement may be confirmed either by inclusion of a signed copy of this addendum with the initial bid or proposal response, or by completion and return of the addendum acknowledgement section of the solicitation. Failure to acknowledge each addendum may prevent the bid or proposal from being considered for award.

This addendum does not change the date for receipt of bids or proposals.

The purpose of this addendum is to respond to the following question:

Question 1: The ITB specifications call for posts at 8' on centers. The detail drawings show 10' on center. Please clarify.

Answer 1: The posts are to be 8' on centers. Please make necessary changes.

Firm Name: _____ Date: _____

Signature: _____ Title: _____

Typed/Printed Name: _____